

**Minutes of Pre-Bid Meeting for
Road Rehabilitation Works under the Contract RSPSP/W3/01:
“Rehabilitation of M2 Chisinau-Sorooca road km 5+733 to km 26+200”**

The conference was held on September 12, 2011; 9:00 a.m. (local time) at the State Road Administration office and attended by the following representatives:

Client’s representatives

- Mr. Fiodor Grebencio, Deputy Chief-Manager, State Road Administration
- Mr. Gheorghe Curmei, Head of Investment Department, State Road Administration
- Mr. Martin Bennett, IEMC, Scott Wilson Ltd

Bidder’s representatives:

1. Strabag AG

- Mr. Baromisa Sardan
- Mr. Kappl Peter
- Mr. Zekany Alexandru

2. Taddei SPA

- Angelo Marzulli

3. Valmo representing JV Construcões Gabriel AS Couto SA in association with Empresa de Construcões Amandio Carvalho SA and Rosas Construtores SA

- Joao Cardoso
- Cocieri Ion

Programme:

It was agreed that a site visit was not required.

Pre-Bid Meeting:

The following questions were raised during the meeting and answers are provided below.

Question 1:

Is a list of borrow pits and quarries for Moldova and the region available?

Answer 1:

It is the Bidder’s responsibility to locate material sources.

Question 2:

The Bill of Quantities is not mentioned in paragraph 2 of the draft Contract Agreement .

Answer 2:

Item (viii) [the completed schedules] includes the Bill of Quantities.

Question 3:

The internet links for all 3 volumes do not work.

Answer 3:

Please click the following links to download the files:

- Volume 1 Bidding Documents
<http://www.asd.md/ENG/docs/Volume 1 Bidding Documents.pdf>
- Volume 2 Technical Specifications
<http://www.asd.md/ENG/docs/Volume 2 Technical Specifications.pdf>
- Volume 3 Drawings:
http://www.asd.md/ENG/docs/Lot2_Volume3 Drawings_eng.pdf

Question 4:

What is the standard kerb height in Moldova?

Answer 4:

Please refer to drawing CRS-DA-1 included in Volume 3 Drawings of Bidding Documents.

Question 5:

What is the thickness of asphalt to be removed on bridges?

Answer 5:

Normally 7 cm

Question 6:

What is the thickness of asphalt on bridge decks?

Answer 6:

7 cm

Question 7:

When will the contract be awarded and when will the works commence?

Answer 7:

It is planned for the contract to be awarded in January 2012 with commencement in early Spring 2012.